

© Copyright April 2009 S-Box LLC.
 Reproduction or distribution without the
 Express written permission of S-Box LLC
 Can be the basis of legal action



Project No.	BDO
Drawn By:	BJS
Checked By:	BDO
Approved By:	RMM

Project No.	J2096140
Scale	1" = 1'
File No.	J2096140
Date	APRIL 2009

Terracon
 Consulting Engineers and Scientists
 201 Hanger Hill Road
 Rockville, MD 20851-5000
 FAX: (301) 771-5800

36" H-20 LOADING CROSS SECTION
 S-BOX SEWAGE AND WASTEWATER TREATMENT SYSTEM
 S-BOX LLC
 66 OLIVARIUS PARKWAY
 MIDDLETOWN, CT 06457

FIG. No.
 1

MINIMUM 1½" THICK
 BITUMINOUS
 CONCRETE (ASPHALT)
 OR MINIMUM 4" THICK
 CRUSHED STONE

WELL GRADED CRUSHED ANGULAR GRANULAR BASE
 WITH 2 INCH MAXIMUM PARTICLE SIZE AND NO
 MORE THAN 10% FINES PASSING No. 200 SIEVE,
 COMPACTED TO AT LEAST 95% OF THE MAXIMUM
 DRY DENSITY, AS DETERMINED BY ASTM D1557, METHOD C.

